

MARICOPA COUNTY AIR QUALITY DEPARTMENT TANK TRUCK LEAK CERTIFICATION CHECK LIST

CARGO TANK LEAK TEST DATE NOTIFICATION DATE/TIME: (NOT NECESSARY FOR TESTS DONE OUTSIDE MARICOPA COUNTY))	
WE HEREBY CERTIFY THAT A LEAKAGE TEST WAS PERFORMED ON A CARGO TANK VESSEL PER MARICOPA							,				
OWNER:						PHONE:					
ADDRESS:						MFG.'S SERIAL NO.:					
CITY/STATE/ZIP:						UNIT NO.:					
TEST SITE (CITY/STATE):						TANK CAPACITY:					
DETERMINATION OF VAPOR TIGHTNESS OF CARGO TANK PER EPA REGULATION 40 CFR PART 60 APPENDIX							A (METHOD 27)				
PRE-TEST PRO	CEDURE	(CHECK	<u>√)</u>								
☐ TRUCK/TRAILER PURGED OF GASOLINE VAPORS ☐ TO CONTROL DEVICE (MCAPC PERMIT #) OR ☐ PREVIOUS LOAD DIESEL ☐ TANK TRUCK/TRAILER IN SHADE MORE THAT ONE (1) HOUR ☐ TANK TRUCK/TRAILER GROUNDED AND ALL DOME COVERS OPENED AND CLOSED											
□ VAPOR HOSE (BELONGING TO UNIT) ATTACHED TO UNIT, TEST CAP ON VAPOR HOSE □ PRESSURE SOURCE ATTACHED TO VAPOR HOSE											
MANOMETER ATTACHED TO PRESSURE TAP											
	STAR	T TIME	INITIAL INCHES H ₂ O	FINISH TIME	II	FINAL NCHES H ₂ O	TOTAL P		PASS YES	ED NO	
INITIAL TEST											
DDECCTIDE TEC	т.						•				
PRESSURE TEST: 1. OPEN SHUT OFF VALVE IN THE VAPOR RECOVERY HOSE CAP. SLOWLY PRESSURIZE THE TANK (OR FIRST COMPARTMENT) TO 18 INCHES H ₂ O. 2. CLOSE											
			ECOVERY HOSE CAP NK TO STABILIZE. A								
			TABILIZED. (ALLOW							WIINO I ES	
(REPEAT RUNS UN	TIL TWO CO	ONNECTIVES					,	ı			
	STAR	T TIME	INITIAL INCHES H ₂ O	FINISH TIME	II	FINAL NCHES H ₂ O	TOTAL P		PASS YES	ED NO	
RUN 1											
RUN 2											
	u .							'			
VAPOR VALVE	LOSS TE	ST:									
1. PRESSURIZE ANI	STABILIZE	E TANK TO 18	S INCHES H ₂ O. CLOSI	E INTERNAL VAPOR	VALVES I	N TANK (ISOLA	ATING THE VAPO	R RETURN LINE	AND MANI	FOLD).	
2. OPEN THE SHUT	OFF VALVE	AND RELIEV	E THE PRESSURE IN	THE VAPOR RETUR	N LINE AN	D MANIFOLD T	TO ATMOSPHERIC	PRESSURE 3.	CLOSE THE	E SHUT	
OFF VALVE AND RE	CORD TIM	E AND PRES	SURE . 4 . AFTER (5)	MINUTES RECORD	THE PRES	SSURE. (ALLOW	VABLE PRESSURI	E INCREASE 5 INC	CHES TOTA	L (2½	
INCHES EACH SIDE OF MANOMETER).					ALE BUILD A LANGE CONTRACTOR OF CONTRACTOR O						
I IANK	K PRESSURE CHES H ₂ O START TIME FINISH T			VADOD DETUDNI I	JE INITELAL	VADOD DETI	LIDNI I INIC CINIAI	TOTAL DESCRIPT	7 DA	CCED	
		START TIM	1E FINISH TIME	VAPOR RETURN LI PRESSURE INCH			URN LINE FINAL E INCHES H ₂ O	TOTAL PRESSURE CHANGE	E PA	SSED NO	
		START TIM	1E FINISH TIME								
. INC		START TIM	ME FINISH TIME								
. INC	HES H ₂ O	START TIM	THE FINISH TIME								
RUN 1 VACUUM TES	HES H ₂ O		FRESSURE/VACUUM	PRESSURE INCE	ES H ₂ O	PRESSURI	E INCHES H ₂ O	CHANGE	YES	NO	
RUN 1 VACUUM TES 1. CONNECT THE V.	HES H ₂ O ST: ACUUM SOU	URCE TO THE		PRESSURE INCH	ES H ₂ O SLOWLY	PRESSURI EVACUATE TH	E INCHES H₂O IE TANK (OR FIR:	CHANGE ST COMPARTMEN	YES NT) TO 6 IN	NO NO CHES	
VACUUM TES 1. CONNECT THE V. H ₂ O. 3. CLOSE THE	HES H₂O ST: ACUUM SOU SHUT OFF V	JRCE TO THE /ALVE, ALLC	PRESSURE/VACUUM	PRESSURE INCE 4 SUPPLY HOSE. 2. 5 STABILIZE, ADJUS	ES H₂O SLOWLY T THE PRE	PRESSURI EVACUATE THE	E INCHES H₂O HE TANK (OR FIR: ESSARY TO MAIN	CHANGE ST COMPARTMEN ITAIN 6 INCHES I	YES NT) TO 6 IN H ₂ O. RECO	NO NO CHES	
VACUUM TES 1. CONNECT THE V. H ₂ O. 3. CLOSE THE INITIAL TIME/PRE	HES H ₂ O T: ACUUM SOU SHUT OFF V SSURE WHE	JRCE TO THE /ALVE, ALLC EN STABILIZ	PRESSURE/VACUUM OW THE PRESSURE TO LED. 4. AT THE END (REPEAT RUNS UN)	PRESSURE INCE 4 SUPPLY HOSE. 2. 5 STABILIZE, ADJUST 6 OF (5) MINUTES, RE	ES H₂O SLOWLY T THE PRE CORD FIN	EVACUATE THE ESSURE IF NECI AL TIME/PRESS S PASS)	E INCHES H₂O HE TANK (OR FIR: ESSARY TO MAIN SURE. (ALLOWA	CHANGE ST COMPARTMEN ITAIN 6 INCHES I BLE PRESSURE D	YES NT) TO 6 IN H ₂ O. RECO PROP EQUA	CHES RD	
VACUUM TES 1. CONNECT THE V. H ₂ O. 3. CLOSE THE INITIAL TIME/PRE	HES H ₂ O ST: ACUUM SOU SHUT OFF V SSURE WHE SIDE OF MA	JRCE TO THE /ALVE, ALLC EN STABILIZ ANOMETER).	PRESSURE/VACUUM OW THE PRESSURE TO ED. 4. AT THE END (REPEAT RUNS UNI	PRESSURE INCE 4 SUPPLY HOSE. 2. 5 STABILIZE, ADJUS 6 OF (5) MINUTES, REFIL TWO CONNECT	SLOWLY T THE PRE CORD FIN	EVACUATE THESSURE IF NECIFAL TIME/PRESS S PASS) FINAL	E INCHES H ₂ O HE TANK (OR FIR: ESSARY TO MAIN SURE. (ALLOWA	CHANGE ST COMPARTMEN STAIN 6 INCHES F BLE PRESSURE D RESSURE	YES NT) TO 6 IN H ₂ O. RECO ROP EQUA	CHES RD L TO 1	
VACUUM TES 1. CONNECT THE V. H ₂ O. 3. CLOSE THE INITIAL TIME/PRE	HES H ₂ O ST: ACUUM SOU SHUT OFF V SSURE WHE SIDE OF MA	JRCE TO THE /ALVE, ALLC EN STABILIZ	PRESSURE/VACUUM OW THE PRESSURE TO LED. 4. AT THE END (REPEAT RUNS UN)	PRESSURE INCE 4 SUPPLY HOSE. 2. 5 STABILIZE, ADJUST 6 OF (5) MINUTES, RE	SLOWLY T THE PRE CORD FIN	EVACUATE THE ESSURE IF NECI AL TIME/PRESS S PASS)	E INCHES H₂O HE TANK (OR FIR: ESSARY TO MAIN SURE. (ALLOWA	CHANGE ST COMPARTMEN STAIN 6 INCHES F BLE PRESSURE D RESSURE	YES NT) TO 6 IN H ₂ O. RECO PROP EQUA	CHES RD	
RUN 1 VACUUM TES 1. CONNECT THE V. H ₂ O. 3. CLOSE THE INITIAL TIME/PREINCH (½ INCH EACH	HES H ₂ O ST: ACUUM SOU SHUT OFF V SSURE WHE SIDE OF MA	JRCE TO THE /ALVE, ALLC EN STABILIZ ANOMETER).	PRESSURE/VACUUM OW THE PRESSURE TO ED. 4. AT THE END (REPEAT RUNS UNI	PRESSURE INCE 4 SUPPLY HOSE. 2. 5 STABILIZE, ADJUS 6 OF (5) MINUTES, REFIL TWO CONNECT	SLOWLY T THE PRE CORD FIN	EVACUATE THESSURE IF NECIFAL TIME/PRESS S PASS) FINAL	E INCHES H ₂ O HE TANK (OR FIR: ESSARY TO MAIN SURE. (ALLOWA	CHANGE ST COMPARTMEN STAIN 6 INCHES F BLE PRESSURE D RESSURE	YES NT) TO 6 IN H ₂ O. RECO ROP EQUA	CHES RD L TO 1	
RUN 1 VACUUM TES 1. CONNECT THE V. H ₂ O. 3. CLOSE THE INITIAL TIME/PREINCH (½ INCH EACH	HES H ₂ O ST: ACUUM SOU SHUT OFF V SSURE WHE SIDE OF MA	JRCE TO THE /ALVE, ALLC EN STABILIZ ANOMETER).	PRESSURE/VACUUM OW THE PRESSURE TO ED. 4. AT THE END (REPEAT RUNS UNT	PRESSURE INCE 4 SUPPLY HOSE. 2. 5 STABILIZE, ADJUS 6 OF (5) MINUTES, REFIL TWO CONNECT	SLOWLY T THE PRE CORD FIN	EVACUATE THESSURE IF NECIFAL TIME/PRESS S PASS) FINAL	E INCHES H ₂ O HE TANK (OR FIR: ESSARY TO MAIN SURE. (ALLOWA	CHANGE ST COMPARTMEN STAIN 6 INCHES F BLE PRESSURE D RESSURE	YES NT) TO 6 IN H ₂ O. RECO ROP EQUA	CHES RD L TO 1	
RUN 1 VACUUM TES 1. CONNECT THE V. H ₂ O. 3. CLOSE THE INITIAL TIME/PRE: INCH (½ INCH EACH RUN 1 RUN 2	HES H ₂ O ST: ACUUM SOU SHUT OFF V SSURE WHE SIDE OF M STAR	JRCE TO THE /ALVE, ALLC EN STABILIZ ANOMETER). T TIME	PRESSURE/VACUUM OW THE PRESSURE TO ED. 4. AT THE END (REPEAT RUNS UNT	PRESSURE INCE 4 SUPPLY HOSE. 2. 5 STABILIZE, ADJUS 6 OF (5) MINUTES, RE FIL TWO CONNECT FINISH TIME	SLOWLY T THE PRE CORD FIN IVES RUN	EVACUATE THE ESSURE IF NECI (AL TIME/PRESS (S PASS) FINAL NCHES H ₂ O	E INCHES H ₂ O HE TANK (OR FIRST ESSARY TO MAIN SURE. (ALLOWA TOTAL P. CHA	CHANGE ST COMPARTMEN ITAIN 6 INCHES F BLE PRESSURE D RESSURE NGE	YES NT) TO 6 IN H ₂ O. RECO ROP EQUA	CHES RD L TO 1	
RUN 1 VACUUM TES 1. CONNECT THE V. H ₂ O. 3. CLOSE THE INITIAL TIME/PRE: INCH (½ INCH EACH RUN 1 RUN 2	ST: ACUUM SOU SHUT OFF V SSURE WHE SIDE OF MA STAR	JRCE TO THE /ALVE, ALLC EN STABILIZ ANOMETER). T TIME	PRESSURE/VACUUM OW THE PRESSURE TO EED. 4. AT THE END (REPEAT RUNS UN' INITIAL INCHES H ₂ O	PRESSURE INCE 4 SUPPLY HOSE. 2. 5 STABILIZE, ADJUS 6 OF (5) MINUTES, RE FIL TWO CONNECT FINISH TIME	SLOWLY T THE PRE CORD FIN IVES RUN	EVACUATE THE ESSURE IF NECI (AL TIME/PRESS (S PASS) FINAL NCHES H ₂ O	E INCHES H ₂ O HE TANK (OR FIRST ESSARY TO MAIN SURE. (ALLOWA TOTAL P. CHA	CHANGE ST COMPARTMEN ITAIN 6 INCHES F BLE PRESSURE D RESSURE NGE	YES NT) TO 6 IN H ₂ O. RECO ROP EQUA	CHES RD L TO 1	
RUN 1 VACUUM TES 1. CONNECT THE V. H ₂ O. 3. CLOSE THE INITIAL TIME/PREINCH (½ INCH EACH RUN 1 RUN 2 LIST DEFECTS A SEALS/GAS	ST: ACUUM SOU SHUT OFF V SSURE WHE SIDE OF MA STAR	JRCE TO THE /ALVE, ALLC EN STABILIZ ANOMETER). T TIME RS NECESS	PRESSURE/VACUUM OW THE PRESSURE TO EED. 4. AT THE END (REPEAT RUNS UN' INITIAL INCHES H ₂ O	PRESSURE INCE 4 SUPPLY HOSE. 2. 5 STABILIZE, ADJUS 6 OF (5) MINUTES, RE FIL TWO CONNECT FINISH TIME	SLOWLY T THE PRE CORD FIN IVES RUN	EVACUATE THE ESSURE IF NECI (AL TIME/PRESS (S PASS) FINAL NCHES H ₂ O	E INCHES H ₂ O HE TANK (OR FIRST ESSARY TO MAIN SURE. (ALLOWA TOTAL P. CHA	CHANGE ST COMPARTMEN ITAIN 6 INCHES F BLE PRESSURE D RESSURE NGE	YES NT) TO 6 IN H ₂ O. RECO ROP EQUA	CHES RD L TO 1	
RUN 1 VACUUM TES 1. CONNECT THE V. H ₂ O. 3. CLOSE THE INITIAL TIME/PRES INCH (½ INCH EACH RUN 1 RUN 2 LIST DEFECTS A SEALS/GAS INTERNAL	ST: ACUUM SOU SHUT OFF V SSURE WHE SIDE OF MA STAR	JRCE TO THE /ALVE, ALLC EN STABILIZ ANOMETER). T TIME RS NECESS	PRESSURE/VACUUM OW THE PRESSURE TO EED. 4. AT THE END (REPEAT RUNS UN' INITIAL INCHES H ₂ O	PRESSURE INCE 4 SUPPLY HOSE. 2. 5 STABILIZE, ADJUS 6 OF (5) MINUTES, RE FIL TWO CONNECT FINISH TIME	SLOWLY T THE PRE CORD FIN IVES RUN	EVACUATE THE ESSURE IF NECI (AL TIME/PRESS (S PASS) FINAL NCHES H ₂ O	E INCHES H ₂ O HE TANK (OR FIRST ESSARY TO MAIN SURE. (ALLOWA TOTAL P. CHA	CHANGE ST COMPARTMEN ITAIN 6 INCHES F BLE PRESSURE D RESSURE NGE	YES NT) TO 6 IN H ₂ O. RECO ROP EQUA	CHES RD L TO 1	
RUN 1 VACUUM TES 1. CONNECT THE V. H20. 3. CLOSE THE INITIAL TIME/PRESINCH (1/2 INCH EACH RUN 1 RUN 2 LIST DEFECTS A SEALS/GAS INTERNAL VENTS	ST: ACUUM SOU SHUT OFF V SSURE WHE SIDE OF MA STAR	JRCE TO THE /ALVE, ALLC EN STABILIZ ANOMETER). T TIME RS NECESS	PRESSURE/VACUUM OW THE PRESSURE TO EED. 4. AT THE END (REPEAT RUNS UN' INITIAL INCHES H ₂ O	PRESSURE INCE 4 SUPPLY HOSE. 2. 5 STABILIZE, ADJUS 6 OF (5) MINUTES, RE FIL TWO CONNECT FINISH TIME	SLOWLY T THE PRE CORD FIN IVES RUN	EVACUATE THE ESSURE IF NECI (AL TIME/PRESS (S PASS) FINAL NCHES H ₂ O	E INCHES H ₂ O HE TANK (OR FIRST ESSARY TO MAIN SURE. (ALLOWA TOTAL P. CHA	CHANGE ST COMPARTMEN ITAIN 6 INCHES F BLE PRESSURE D RESSURE NGE	YES NT) TO 6 IN H ₂ O. RECO ROP EQUA	CHES RD L TO 1	
RUN 1 VACUUM TES 1. CONNECT THE V. H ₂ O. 3. CLOSE THE INITIAL TIME/PREINCH (½ INCH EACH RUN 1 RUN 2 LIST DEFECTS A SEALS/GAS INTERNAL VENTS WELDING	ST: ACUUM SOUSHUT OFF VSSURE WHE SIDE OF MA STAR ND REPAIL SKETS VALVES	JRCE TO THE /ALVE, ALLC EN STABILIZ ANOMETER). T TIME RS NECESS	PRESSURE/VACUUM OW THE PRESSURE TO EED. 4. AT THE END (REPEAT RUNS UN' INITIAL INCHES H ₂ O	PRESSURE INCE 4 SUPPLY HOSE. 2. 5 STABILIZE, ADJUS 6 OF (5) MINUTES, RE FIL TWO CONNECT FINISH TIME	SLOWLY T THE PRE CORD FIN IVES RUN	EVACUATE THE ESSURE IF NECI (AL TIME/PRESS (S PASS) FINAL NCHES H ₂ O	E INCHES H ₂ O HE TANK (OR FIRST ESSARY TO MAIN SURE. (ALLOWA TOTAL P. CHA	CHANGE ST COMPARTMEN ITAIN 6 INCHES F BLE PRESSURE D RESSURE NGE	YES NT) TO 6 IN H ₂ O. RECO ROP EQUA	CHES RD L TO 1	
RUN 1 VACUUM TES 1. CONNECT THE V. H ₂ O. 3. CLOSE THE INITIAL TIME/PREINCH (½ INCH EACH RUN 1 RUN 2 LIST DEFECTS A SEALS/GAS INTERNAL VENTS WELDING VAPOR REC	ST: ACUUM SOUSHUT OFF VSSURE WHE SIDE OF MA STAR ND REPAIL SKETS VALVES	JRCE TO THE /ALVE, ALLC EN STABILIZ ANOMETER). T TIME RS NECESS	PRESSURE/VACUUM OW THE PRESSURE TO EED. 4. AT THE END (REPEAT RUNS UN' INITIAL INCHES H ₂ O	PRESSURE INCE 4 SUPPLY HOSE. 2. 5 STABILIZE, ADJUS 6 OF (5) MINUTES, RE FIL TWO CONNECT FINISH TIME	SLOWLY T THE PRE CORD FIN IVES RUN	EVACUATE THE ESSURE IF NECI (AL TIME/PRESS (S PASS) FINAL NCHES H ₂ O	E INCHES H ₂ O HE TANK (OR FIRST ESSARY TO MAIN SURE. (ALLOWA TOTAL P. CHA	CHANGE ST COMPARTMEN ITAIN 6 INCHES F BLE PRESSURE D RESSURE NGE	YES NT) TO 6 IN H ₂ O. RECO ROP EQUA	CHES RD L TO 1	
VACUUM TES 1. CONNECT THE V. H2O. 3. CLOSE THE INITIAL TIME/PRES INCH (½ INCH EACH RUN 1 RUN 2 LIST DEFECTS A SEALS/GAS INTERNAL VENTS WELDING VAPOR REC DOME	ST: ACUUM SOU SHUT OFF V SSURE WHE SIDE OF MA STAR ND REPAI SKETS VALVES	JRCE TO THE /ALVE, ALLC EN STABILIZ ANOMETER). T TIME RS NECESS	PRESSURE/VACUUM OW THE PRESSURE TO EED. 4. AT THE END (REPEAT RUNS UN' INITIAL INCHES H ₂ O	PRESSURE INCE 4 SUPPLY HOSE. 2. 5 STABILIZE, ADJUS 6 OF (5) MINUTES, RE FIL TWO CONNECT FINISH TIME	SLOWLY T THE PRE CORD FIN IVES RUN	EVACUATE THE ESSURE IF NECI (AL TIME/PRESS (S PASS) FINAL NCHES H ₂ O	E INCHES H ₂ O HE TANK (OR FIRST ESSARY TO MAIN SURE. (ALLOWA TOTAL P. CHA	CHANGE ST COMPARTMEN ITAIN 6 INCHES F BLE PRESSURE D RESSURE NGE	YES NT) TO 6 IN H ₂ O. RECO ROP EQUA	CHES RD L TO 1	
RUN 1 VACUUM TES 1. CONNECT THE V. H20. 3. CLOSE THE INITIAL TIME/PRES INCH (1/2 INCH EACH RUN 1 RUN 2 LIST DEFECTS A INTERNAL VENTS WELDING VAPOR REC DOME GENERAL I	HES H ₂ O ST: ACUUM SOU SHUT OFF V SSURE WHE SIDE OF M ₂ STAR ND REPAI SKETS VALVES COVERY	JRCE TO THE /ALVE, ALLC EN STABILIZ ANOMETER). T TIME RS NECESS	PRESSURE/VACUUM OW THE PRESSURE TO EED. 4. AT THE END (REPEAT RUNS UN' INITIAL INCHES H ₂ O	PRESSURE INCE 4 SUPPLY HOSE. 2. 5 STABILIZE, ADJUS 6 OF (5) MINUTES, RE FIL TWO CONNECT FINISH TIME	SLOWLY T THE PRE CORD FIN IVES RUN	EVACUATE THE ESSURE IF NECI (AL TIME/PRESS (S PASS) FINAL NCHES H ₂ O	E INCHES H ₂ O HE TANK (OR FIRST ESSARY TO MAIN SURE. (ALLOWA TOTAL P. CHA	CHANGE ST COMPARTMEN ITAIN 6 INCHES F BLE PRESSURE D RESSURE NGE	YES NT) TO 6 IN H ₂ O. RECO ROP EQUA	CHES RD L TO 1	
VACUUM TES 1. CONNECT THE V. H2O. 3. CLOSE THE INITIAL TIME/PRES INCH (½ INCH EACH RUN 1 RUN 2 LIST DEFECTS A SEALS/GAS INTERNAL VENTS WELDING VAPOR REC DOME	HES H ₂ O ST: ACUUM SOU SHUT OFF V SSURE WHE SIDE OF M ₂ STAR ND REPAI SKETS VALVES COVERY	JRCE TO THE /ALVE, ALLC EN STABILIZ ANOMETER). T TIME RS NECESS	PRESSURE/VACUUM OW THE PRESSURE TO EED. 4. AT THE END (REPEAT RUNS UN' INITIAL INCHES H ₂ O	PRESSURE INCE 4 SUPPLY HOSE. 2. 5 STABILIZE, ADJUS 6 OF (5) MINUTES, RE FIL TWO CONNECT FINISH TIME	SLOWLY T THE PRE CORD FIN IVES RUN	EVACUATE THE ESSURE IF NECI (AL TIME/PRESS (S PASS) FINAL NCHES H ₂ O	E INCHES H ₂ O HE TANK (OR FIRST ESSARY TO MAIN SURE. (ALLOWA TOTAL P. CHA	CHANGE ST COMPARTMEN ITAIN 6 INCHES F BLE PRESSURE D RESSURE NGE	YES NT) TO 6 IN H ₂ O. RECO ROP EQUA	CHES RD L TO 1	
RUN 1 VACUUM TES 1. CONNECT THE V. H20. 3. CLOSE THE INITIAL TIME/PRES INCH (1/2 INCH EACH RUN 1 RUN 2 LIST DEFECTS A INTERNAL VENTS WELDING VAPOR REC DOME GENERAL I	ST: ACUUM SOUSHUT OFF VSURE WHE SIDE OF MARKETS VALVES COVERY MAINTEN GAUGE	JRCE TO THE /ALVE, ALLC EN STABILIZ ANOMETER). T TIME RS NECESS	PRESSURE/VACUUM OW THE PRESSURE TO CED. 4. AT THE END (REPEAT RUNS UN) INITIAL INCHES H2O SARY TO PASS VA	PRESSURE INCE 4 SUPPLY HOSE. 2. 5 STABILIZE, ADJUS 6 OF (5) MINUTES, RE FIL TWO CONNECT FINISH TIME	SLOWLY T THE PRE CORD FIN IVES RUN	EVACUATE THE ESSURE IF NECI (AL TIME/PRESS (S PASS) FINAL NCHES H ₂ O	E INCHES H ₂ O HE TANK (OR FIRST ESSARY TO MAIN SURE. (ALLOWA TOTAL P. CHA	CHANGE ST COMPARTMEN ITAIN 6 INCHES F BLE PRESSURE D RESSURE NGE	YES NT) TO 6 IN H ₂ O. RECO ROP EQUA	CHES RD L TO 1	
RUN 1 VACUUM TES 1. CONNECT THE V. H ₂ O. 3. CLOSE THE INITIAL TIME/PRES INCH (½ INCH EACH RUN 1 RUN 2 LIST DEFECTS A SEALS/GAS INTERNAL VENTS WELDING VAPOR REC DOME DOME PRESSURE	ST: ACUUM SOUSHUT OFF VSURE WHE SIDE OF MAND REPAIRSKETS VALVES COVERY MAINTEN GAUGE PECIFY	JRCE TO THE /ALVE, ALLC EN STABILIZ ANOMETER). T TIME RS NECESS	PRESSURE/VACUUM OW THE PRESSURE TO ED. 4. AT THE END (REPEAT RUNS UNI INITIAL INCHES H ₂ O	PRESSURE INCE 4 SUPPLY HOSE. 2. 5 STABILIZE, ADJUS 6 OF (5) MINUTES, RE FIL TWO CONNECT FINISH TIME	SLOWLY T THE PRE CORD FIN IVES RUN TEST: (I	EVACUATE THE ESSURE IF NECI (AL TIME/PRESS (S PASS) FINAL NCHES H ₂ O	E INCHES H ₂ O HE TANK (OR FIR: ESSARY TO MAIN SURE. (ALLOWA TOTAL P. CHA DONE PRIOR T	CHANGE ST COMPARTMEN ITAIN 6 INCHES F BLE PRESSURE D RESSURE NGE	YES NT) TO 6 IN H ₂ O. RECO PROP EQUA PAS YES	CHES RD L TO 1 SED NO	
NO NO	ST: ACUUM SOUSHUT OFF VSURE WHE SIDE OF MANUE STARE ND REPAIL SKETS VALVES COVERY MAINTEN GAUGE PECIFY EY:	JRCE TO THE VALVE, ALLO EN STABILIZ ANOMETER). TTIME RS NECESS JANCE REPAIR) TESTED BY	PRESSURE/VACUUM OW THE PRESSURE TO ED. 4. AT THE END (REPEAT RUNS UNI INITIAL INCHES H ₂ O	PRESSURE INCE A SUPPLY HOSE. 2. O STABILIZE, ADJUS O OF (5) MINUTES, RESILTING CONNECT FINISH TIME POR TIGHTNESS	SLOWLY T THE PRE CORD FIN IVES RUN TEST: (I	EVACUATE THE SSURE IF NECIFICAL TIME/PRESS S PASS) FINAL NCHES H ₂ O	E INCHES H ₂ O HE TANK (OR FIR: ESSARY TO MAIN SURE. (ALLOWA TOTAL P. CHA DONE PRIOR T	CHANGE ST COMPARTMEN STAIN 6 INCHES F BLE PRESSURE D RESSURE NGE CO TESTING	YES NT) TO 6 IN H ₂ O. RECO PROP EQUA PAS YES	CHES RD L TO 1 SED NO	
RUN 1 VACUUM TES 1. CONNECT THE V. H2O. 3. CLOSE THE INITIAL TIME/PRESINCH (1/2 INCH EACH RUN 1 RUN 2 LIST DEFECTS A SEALS/GAS INTERNAL VENTS WELDING VAPOR REG DOME DOME PRESSURE OTHER (SI TEST PERFORMED E	ST: ACUUM SOUSHUT OFF VSSURE WHE SIDE OF MAINTEN GAUGE PECIFY TY: BE COMP	URCE TO THE VALVE, ALLC EN STABILIZ ANOMETER). T TIME RS NECESS VALUE	PRESSURE/VACUUM OW THE PRESSURE TO CED. 4. AT THE END (REPEAT RUNS UN) INITIAL INCHES H ₂ O SARY TO PASS VA	PRESSURE INCE A SUPPLY HOSE. 2. O STABILIZE, ADJUS O OF (5) MINUTES, RE FIL TWO CONNECT FINISH TIME POR TIGHTNESS THE TEST OCK/TRAILER TE	SLOWLY T THE PRE CORD FIN IVES RUN TEST: (I	EVACUATE THE ESSURE IF NECI AL TIME/PRESS S PASS) FINAL NCHES H ₂ O LIST REPAIRS	E INCHES H ₂ O HE TANK (OR FIR: ESSARY TO MAIN SURE. (ALLOWA TOTAL P. CHA DONE PRIOR T	CHANGE ST COMPARTMEN STAIN 6 INCHES F BLE PRESSURE D RESSURE NGE CO TESTING	YES NT) TO 6 IN H ₂ O. RECO PAS YES TEST IS D	CHES RD L TO 1 SED NO	